



560 WALL STREET SUITE C
AUBURN, CA 95603
FAX: 530-885-9505
Email: ron@lichau.com

AN ARCHITECTURAL & PLANNING GROUP

NEWCASTLE FIRE STATION ADDENDUM #3

PRE-BID QUESTIONS

Could you verify what type of racking will be needed?

1) Specifically looking at the size of the **UPS model** requirements by County or City Chief Information Officer.

2) Rack to be open or enclosed?

Response: The Rack is open. Approximately 24" wide x18" deep x 24" tall for radios, amplifier, and UPS