

## Phil Herzer

---

**From:** Joshua Lelko <jlelko@pcwa.net>  
**Sent:** Friday, September 27, 2013 8:29 AM  
**To:** 'phil@rosevilledesigngroup.com'  
**Subject:** PCWA Water Connection Charges  
**Attachments:** 2013 Zone 1 WCC.pdf; Project Review Form\_071213.pdf; Meter Request Form.pdf

Hi Phil,

*Below is general information that is important for projects within PCWA boundary. For service needs greater than a 1.5" meter, we look at the total maximum day demand in gallons per day, divide by 1150gpd (for 1 EDU) and multiply by the current rate for 1 EDU (\$16,444) as of this email. Example, total daily demand is 11,500gpd ÷ 1150gpd/EDU = 10 EDUs × \$16,444 = \$164,440 in Water Connection Charges connection charges. We also look at the maximum flow rate, if this exceeds that of the meter that is being applied for, we upsize the meter to the appropriate size and charge the minimum WCC. I hope all of this makes sense, if not please feel free to contact us.*

Please find attached, the information you had requested. 2013 Zone 1 WCC contains the current water connection charges. We are unable to determine the exact Water Connection Charge without knowing actual flow demands. Also attached are the project application and meter application. These are to be completed and submitted with the initial plan check along with the application fee, plan check deposit, three (3) sets of plans and an approved tentative map. Please note that one meter application is to be completed for each type and size of meter. The current Project Application Fee is \$109 with a Plan Check Deposit of \$1000 for a total of \$1109. There may be additional Plan Checking Deposits required depending on the extent of the plan checking process.

Please visit our website to view the current [Facilities Agreement Process](#), [Project Plans Checklist](#), [Improvement Standards, Specifications, and Drawings](#).

Please include the Agency's facilities on the improvement plans, identify any potential conflicts, and submit the improvement plans to the agency for review prior to construction. If you would like to obtain distribution maps or record drawings for the project location, please contact Steve Dowden in our Mapping Department ([sdowden@pcwa.net](mailto:sdowden@pcwa.net), (530) 823-4892). Please be advised that it is the contractor's responsibility to determine actual location of underground utilities. Only actual excavation will reveal the true types, extent, size, locations, and depths of existing facilities.

For information regarding billing, account inquires, and current water rates, please contact Customer Service at (530) 823-4850.

Please note that there will also be inspection deposits required prior to the time of construction. Without knowing the full extents of the project, we are unable to determine these at this time.

If you need any further information, please feel free to contact me.

Thank you,

**Josh Lelko**

**Engineering Technician II**  
**Placer County Water Agency**

Technical Services | Engineering Division  
P.O. Box 6570, Auburn, CA 95604

TEL: 530.823.4886 | FAX: 530.823.4884

EMAIL: [jlelko@pcwa.net](mailto:jlelko@pcwa.net) | WEB: [www.pcwa.net](http://www.pcwa.net)

